

AMBIENT ENVIRONMENTAL, INC.

Consulting/Engineering/Remediation
www.ambientenvinc.com
400 North Princeland Court Suite-3
Corona, California 92879
951 272-4730 Phone
951 272-4731 Facsimile
jp@ambientenv.com

July 10, 2019

University of California, Riverside
Planning Design & Construction
1223 University Avenue Suite 240
Riverside, California 92507
Attn: Mr. Dave Bomba

Re: Ambient Air Sampling for the project located at:
Pierce Hall Second Floor and First Floor Lobby University of California
Riverside, California.

To Mr. Bomba,

Ambient air samples were obtained from the second floor and first floor lobby. Samples were obtained by the use of an electric air pump along with a twenty-five millimeter mixed cellulose ester-membrane filters, utilizing a fifty millimeter electrically conductive cowls as specified in 29 CFR 1101.1.


Samples were analyzed in accordance with the requirements of NIOSH Method 7400 Method for Phase Contrast Microscopy (PCM). Personnel involved in the analysis of PCM samples have completed NIOSH course 582 or its equivalent as required by 29 CFR 1101.1. All clearance air samples were less than or equal to the Asbestos Hazard Emergency Response Act (AHERA) 40 CFR Part 763.90 and the Environmental Protection Agency (EPA) asbestos airborne clearance criteria limit of 0.01 fiber per cubic centimeter (f/cc) by PCM.

This Letter of Completion is limited to work performed at the above referenced location. Based upon the air sample results, Ambient Environmental, Inc. can recommend the occupancy of the above referenced locations.

Signed for Ambient Environmental, Inc. by:

John L. Payne

California Certified Asbestos Consultant #93-1226



AMBIENT ENVIRONMENTAL, INC.

CERTIFICATE OF ANALYSIS

CLIENT: University of California Riverside

PROJECT NAME: Pierce Hall Hallway Second Floor and First Floor Lobby University of California Riverside, CA

REPORT DATE: 7-10-19

SAMPLE NUMBER	SAMPLE LOCATION	DATE SAMPLE	FLOW RATE (L/MIN)	TIME (MIN)	SAMPLE VOLUME (LITER)	FIBER COUNT	D/L	FIBER /CC
01	Ambient-First Floor Lobby	7-9-19	15.0	80	1200	3/100	0.002	<0.01
02	Ambient-Second Floor Hallway	7-9-19	15.0	81	1215	3/100	0.002	<0.01
03	Ambient-Room 2231	7-9-19	15.0	81	1215	3/100	0.002	<0.01
04	Ambient-Second Floor Hallway	7-9-19	15.0	80	1200	4/100	0.002	<0.01
05	Ambient-Room 2126	7-9-19	15.0	82	1275	3/100	0.002	<0.01
06	Ambient-Room 2133	7-9-19	15.0	81	1215	4/100	0.002	<0.01
07	Ambient-Room 2112	7-9-19	15.0	82	1275	3/100	0.002	<0.01

DL=Detection Limit-I certify that the above samples were analyzed in strict compliance with NIOSH 7400 standards and regulations.

Signed for John L. Payne Certified Asbestos Consultant