

AMBIENT ENVIRONMENTAL, INC.

Consulting/Engineering/Remediation  
www.ambientenvinc.com  
400 North Princland Court Suite-3  
Corona, California 92879  
951 272-4730 Phone  
951 272-4731 Facsimile  
jp@ambientenv.com

August 31, 2019

University of California, Riverside  
Planning Design & Construction  
1223 University Avenue Suite 240  
Riverside, California 92507  
Attn: Mr. John Franklin Senior Project Manager

Re: Final Clearance Air Sampling for the project located at:  
Pierce Hall First Floor Center Hallway University of California Riverside,  
California.

To Mr. Franklin,


Final clearance air samples were obtained after the removal of the vinyl floor tile and mastic within the contained work area. After a thorough visual inspection inside the work area, Ambient Environmental obtained final air clearance samples. Samples were obtained by the use of an electric air pump along with a twenty-five millimeter mixed cellulose ester-membrane filters, utilizing a fifty millimeter electrically conductive cowls as specified in 29 CFR 1101.1.

Samples were analyzed in accordance with the requirements of NIOSH Method 7400 Method for Phase Contrast Microscopy (PCM). Personnel involved in the analysis of PCM samples have completed NIOSH course 582 or its equivalent as required by 29 CFR 1101.1. All clearance air samples were less than or equal to the Asbestos Hazard Emergency Response Act (AHERA) 40 CFR Part 763.90 and the Environmental Protection Agency (EPA) asbestos airborne clearance criteria limit of 0.01 fiber per cubic centimeter (f/cc) by PCM.

This Letter of Completion is limited to work performed at the above referenced location. Based upon the air sample results and visual inspection, Ambient Environmental, Inc. can recommend the re-occupancy of the above referenced location.

Signed for Ambient Environmental, Inc. by:

John L. Payne  
California Certified Asbestos Consultant #93-1226



AMBIENT ENVIRONMENTAL, INC.

## CERTIFICATE OF ANALYSIS

CLIENT: University of California Riverside  
PROJECT NAME: Pierce Hall Hallway First Floor Center Hallway  
REPORT DATE: 9-31-19

SAMPLE NUMBER	SAMPLE LOCATION	DATE SAMPLE	FLOW RATE (L/MIN)	TIME (MIN)	SAMPLE VOLUME (LITER)	FIBER COUNT	D/L	FIBER /CC
01	Clearance- Inside Hallway	8-31-19	10.0	124	1240	9/100	0.002	<0.01
02	Clearance- Inside Hallway	8-31-19	10.0	124	1240	12/100	0.002	<0.01
03	Clearance- Inside Hallway	8-31-19	10.0	123	1230	11/100	0.002	<0.01
04	Clearance- Inside Hallway	8-31-19	10.0	122	1220	12/100	0.002	<0.01

DL=Detection Limit-I certify that the above samples were analyzed in strict compliance with NIOSH 7400 standards and regulations.

---

Signed for John L. Payne  
Certified Asbestos Consultant 93-1226