



AMBIENT ENVIRONMENTAL, INC.

Consulting/Engineering/Remediation
www.ambientenvinc.com
400 North Princeland Court Suite-3
Corona, California 92879
951 272-4730 Phone
951 272-4731 Facsimile
jp@ambientenv.com

July 8, 2019

University of California, Riverside
Planning Design & Construction
1223 University Avenue Suite 240
Riverside, California 92507
Attn: Mr. Dave Bomba

Re: Final Clearance Air Sampling for the project located at:
Pierce Hall First Floor University of California Riverside, California.

To Mr. Bomba,


Final clearance air samples were obtained after the cleanup of the asbestos containing dust inside the rooms and hallways on the first floor within the contained work area. After a thorough visual inspection for any visible dust remaining inside the work area, Ambient Environmental obtained final air clearance. Samples were obtained by the use of an electric air pump along with a twenty-five millimeter mixed cellulose ester-membrane filters, utilizing a fifty millimeter electrically conductive cowls as specified in 29 CFR 1101.1.

Samples were analyzed in accordance with the requirements of NIOSH Method 7400 Method for Phase Contrast Microscopy (PCM). Personnel involved in the analysis of PCM samples have completed NIOSH course 582 or its equivalent as required by 29 CFR 1101.1. All clearance air samples were less than or equal to the Asbestos Hazard Emergency Response Act (AHERA) 40 CFR Part 763.90 and the Environmental Protection Agency (EPA) asbestos airborne clearance criteria limit of 0.01 fiber per cubic centimeter (f/cc) by PCM.

This Letter of Completion is limited to work performed at the above referenced location. Based upon the air sample results and visual inspection, Ambient Environmental, Inc. can recommend the re-occupancy of the above referenced location.

Signed for Ambient Environmental, Inc. by:

John L. Payne
California Certified Asbestos Consultant #93-1226



AMBIENT ENVIRONMENTAL, INC.

CERTIFICATE OF ANALYSIS

CLIENT: University of California Riverside
PROJECT NAME: Pierce Hall Hallway First Floor Hallway and Rooms University of California Riverside, CA
REPORT DATE: 7-8-19

SAMPLE NUMBER	SAMPLE LOCATION	DATE SAMPLE	FLOW RATE (L/MIN)	TIME (MIN)	SAMPLE VOLUME (LITER)	FIBER COUNT	D/L	FIBER /CC
01	Clearance- Inside Room 1144	7-8-19	15.0	82	1230	4/100	0.002	<0.01
02	Clearance- Inside Room 1141-1117	7-8-19	15.0	82	1230	5/100	0.002	<0.01
03	Clearance- Inside Room 1132	7-8-19	15.0	81	1215	3/100	0.002	<0.01
04	Clearance- Inside Room 1104	7-8-19	15.0	80	1200	4/100	0.002	<0.01
05	Clearance- Inside Room 1105	7-8-19	15.0	81	1215	3/100	0.002	<0.01
06	Clearance- Inside Hallway	7-8-19	15.0	80	1200	4/100	0.002	<0.01
07	Clearance- Inside Lobby	7-8-19	15.0	80	1200	3/100	0.002	<0.01
08	Clearance- Inside 1225 Hallway	7-8-19	15.0	82	1230	3/100	0.002	<0.01
09	Clearance- Inside Room 1219-1220 Hallway	7-8-19	15.0	82	1230	4/100	0.002	<0.01

DL=Detection Limit I certify that the above samples were analyzed in strict compliance with NIOSH 7400 standards and regulations.

Signed for John L. Payne Certified Asbestos Consultant